क्र० सं०	उपकेन्द्र का नाम	ब्यौरा
5.	सारंगढ़	132/33 के०वी० 1×20 एमवीए, 2, 132 के०वी० फीडर बेज
6.	गोराहकोटा	132/33 के०वी० 1×20 एमवीए, 2, 132 के०वी० फीडर बेज़
7.	इंगोरिया	132/33 के०वी० 1×20 एमवीए, 2, 132 के०वी० फीडर बेज
8.	पोरसा	132/33 के०वी० 1×20 एमवीए, 2, 132 के०वी० फीडर बेज
9.	सियोनी मालवा	132/33, के०वी० 1×20 एमवीए, 2, 132 के०वी० फीडर बेज
10.	फूपनार	132/33 के०वी० 1×20 एमवीए, 2, 132 के०वी० फीडर बेज
11.	रायपुर-3	132/33 के०वी० 1×20 एमवीए, 2, 132 के०वी० फीडर बेज़

3.0 बरेली, बीना, खण्डवा, नेपानगर, बीजावर, रायसेन, सिमगा में 1×20 एमवीए का अतिरिक्त ट्रांसफार्मर लगाकर 132 के०वी० उपकेन्द्र का संवर्धन।

4.0 भिण्ड, मालनपुर, पीठमपुर, सतना, रतलाम, सिहोर में अतिरिक्त 1×40 एमवीए का ट्रांसफार्मर लगाकर 132 के०वी० उपकेन्द्र का संवर्धन करना।

5.0 पिछोर और सुवासरा में 1×12.5 एमवीए ट्रांसफार्मर के बदले 1×40 एमवीए का ट्रांसफार्मर लगाकर 132 के०वी० उपकेन्द्र का संवर्धन करना।

6.0 अगार, बिश्रामपुर, चम्पा छोटीखरगौन, दमौह, धानमत्री, दतिया, गादरवाड़ा, ग्वालियर, हरदा, कुशी, मनावर, महासमुन्द, शिवपुरी, उज्जैन में 1×20 एमवीए का ट्रांसफार्मर लगाकर 132 के०वी० उपकेन्द्र का ससंवर्धन करना।

(ग) और (घ) राज्य सरकार ने 1993-96 की अवधि के दौरान पारेषण स्कीमों के लिए केन्द्र सरकार से कोई सहायता नहीं मांगी है।

निजी विद्युत क्षेत्र के कार्यकरण को कारगर बनाने के लिए विधेयक

1807. **श्री दिलीप सिंह जूदेव:** क्या विद्युत मंत्री यह बताने की कृपा करेंगे कि:

(क) क्या सरकार निजी विद्युत क्षेत्र के कार्यकरण को कारगर बनाने के लिए कोई व्यापक विधेयक लाने के संबंध में विचार कर रही है;

(ख) यदि हां, तो तत्संबंधी ब्यौरा क्या है;

(ग) क्या उक्त विधेयक के मसौदे को अंतिम रूप दे दिया गया है; और

(घ) इसे संसद में कब तक पुनःस्थापित किए जाने की संभावना है?

विद्युत मंत्री (श्री पी० आर० कुमारमंगलम्): (क) जी, नहीं। इस समय इस प्रकार का कोई प्रस्ताव सरकार के विचाराधीन नहीं है।

(ख) से (घ) प्रश्न उत्पन्न नहीं होते।

Additional Naphtha for Godavari Power Project

1808. DR. Y. LAKSHMI PRASAD: Will the Minister of POWER be pleased to state:

(a) whether the Andhra Pradesh Government has requested for additional Nephtha allocation for Godavari Gas based Power Project at Kakinada;

(b) If so, the action taken thereon; and

(c) the measures proposed for immediate allocation of additional 60000 MT Naphtha for this project on priority basis?

THE MINISTER OF POWER (SHRI P. R. KUMARAMANGALAM): (a) Yes, Sir.

(b) and (c) The request of the Government of Andhra Pradesh is under consideration.

New Power Projects for Andhra Pradesh

1809. DR. Y. LAKSHMI PRASAD: Will the Minister of POWER be pleased to state:

(a) the agreements entered into by the Power Grid Corporation to supply more power to the southern states; and

(b) the projects sanctioned for Andhra Pradesh during the current year to meet the shortage of power?

THE MINISTER OF POWER (SHRI P. R. KUMARAMANGALAM): (a) Andhra Pradesh & Tamil Nadu have been allocated 24% (211 MW) and 36% (316 MW) out of unallocated quota of NTPC stations in Eastern Region, owing to a surplus situation in the Eastern Region. Agreement has been reached between APSEB/TNEB and NTPC.

POWERGRID transmission system is being used for transmission of Eastern Region power to Southern Region.

(b) One thermal project *viz.* Krishnapatnam 'B' Thermal Power Project (2×260 MW) has been sanctioned by CEA this year for execution in the State of Andhra Pradesh. The Project is to be executed by the Private Sector.

Koel-Karo Hydel Power Project

1810. SHRI SHIBU SOREN: Will the Minister of POWER be pleased to state:

(a) whether it is a fact that Government are contemplating to proceed with the Koel-Karo Hydel Project in the near future;

(b) if so, the details of the plan of action;

(c) the details of land acquisition plans, rates of compensation of lands and measures taken for rehabilitating the displaced persons; and

(d) the number of people to be displaced by the project?

THE MINISTER OF POWER (SHRI P.R. KUMARAMANGALAM): (a) and (b) Yes, Sir. The Koel Karo Project (710 MW) is being processed for an investment decision based on revised cost estimate. The Project will require an investment of Rs. 2433.30 crores based on July, 1998 price level. A pre-PIB meeting was held on 16.11.1998. Project construction would be taken up after investment approval by the Government.

(c) The total estimated requirement of land for the project is 22680 hectares (Ha.) including private land, forest land and Government land. Out of the required land National Hydro-electric Power Corporation (NHPC) has so far acquired 150 Ha. private land. Necessary action for acquisition of further 645 Ha. of private land is under process. Balance quantity of land will be acquired in a phased manner during the execution of the project as per requirement from time to time. The rate of compensation of the land is ranging from approx. Rs. 98,840/- per Ha. (Minimum) to approx. Rs. 1,50730/- per Ha. (Maximum).

MEASURES FOR THE REHABILITATION OF THE DISPLACED PERSONS: The detailed rehabilitation plan to rehabilitate the land oustees has been formulated in pursuance of the directives of the Supreme Court of India.

(d) The number of people to be displaced/affected by the project is estimated at 25,000.

Power needs of N.E. Region

1811. SHRI PARAG CHALIHA: Will the Minister of POWER be pleased to state:

(a) whether any special efforts have been taken/contemplated to be taken by Government to meet the growing power needs of North Eastern Region;

(b) if so, the details thereof; and

(c) if not, the reasons therefor?